

We, IMI Climate Control (IMI International Sp. z o.o), Olewin 50A, 32-300 Olkusz, Poland under the sole responsibility of the manufacturer, hereby declare that:

|                 |                      |
|-----------------|----------------------|
| <b>Product:</b> | <b>Intended use:</b> |
| STAF-R          | Balancing valve      |

| Important informations: |               |                              |         |
|-------------------------|---------------|------------------------------|---------|
| Type:                   | PED Category: | Conformity Assessment Module | CE Mark |
| DN 65-150, PN 16        | Category I    | Module I                     | YES     |


is/are compliant with the relevant Union harmonisation legislation:

|                      |                                    |
|----------------------|------------------------------------|
| <b>Ref. no.:</b>     | <b>Title:</b>                      |
| Directive 2014/68/EU | Pressure Equipment Directive (PED) |

and to the relevant harmonised and other standards used or to the technical specifications:

|                  |                                                                                                                                           |
|------------------|-------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ref. no.:</b> | <b>Title:</b>                                                                                                                             |
| EN 12266-1:2012  | Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory requirements |
| EN 1982:2017     | Copper and copper alloys – Ingots and castings                                                                                            |

Olkusz, 23rd September 2024



Piotr Król  
Quality Manager